

Location	Results 5/26/16	Results 10/14/16	Results 2/23/17	Comments/Remediation
MAM.36.DF	2.9			
MAM.36.SINK	17.0		2.9	
MAM.37.DF	12.0			
MAM.37.SINK	12.0			
MAM.38.DF	2.7			
MAM.38.SINK	4.6			
MAM.39.DF	2.7			
MAM.39.SINK	8.3			
MAM.40.DF	2.9			
MAM.40.SINK	11.0			
MAM.41.DF	8.9			
MAM.42.DF	12.0			
MAM.42.SINK	13.0			
MAM.43.DF	7.3			
MAM.43.SINK	12.0			
MAM.44.DF	6.8			
MAM.44.SINK	3.4			
MAM.45.DF	7.4			
MAM.45.SINK	5.1			
MAM.46.DF	12.0			
MAM.46.SINK	3.8			
MAM.47.DF	6.4			
MAM.47.SINK	4.8			
MAM.48.DF	4.0			
MAM.48.SINK	3.4			
MAM.49.DF	6.2			
MAM.49.SINK	10.0			
MAM.CORR4.ALLIGATOR ALLEY.DF	9.0			
MAM.53.DF	4.4			
MAM.53.SINK	4.5			
MAM.55.DF	4.8			
MAM.55.SINK	4.8			
MAM.56.DF	8.7			
MAM.56.SINK	5.1			
MAM.57.SINK	3.7			
MAM.33.DF	8.8			
MAM.33.SINK	13.0			
MAM.32.DF	10.0			
MAM.32.SINK	11.0			

Location	Results 5/26/16	Results 10/14/16	Results 2/23/17	Comments/Remediation
MAM.PRI.KIT.HANDWASH	9.9			
MAM.PRI.KIT.3BAY.RH	7.7			
MAM.PRI.KIT.COMBI.L	14.0			
MAM.PRI.KIT.HW.DISPENSER	1.6			
MAM.CORR2.CHILDRENS CROSSING.DF	<1.0			
MAM.7.DF	4.8			
MAM.8.DF	2.5			
MAM.8.SINK	11.0			
MAM.24.DF	6.3			
MAM.24.SINK	17.0		10.9	
MAM.23.DF	8.5			
MAM.23.SINK	19.0		6.2	
MAM.9.DF	6.0			
MAM.9.SINK	13.0			
MAM.10.DF	12.0			
MAM.10.SINK	7.1			
MAM.22.DF	7.1			
MAM.21.DF	15.0			
MAM.21.SINK	17.0		24.6	
MAM.11.DF	3.7			
MAM.11.SINK	15.0			
MAM.12.DF	3.3			
MAM.20.DF	3.0			
MAM.19.DF	10.0			
MAM.14.DF	2.3			
MAM.14.SINK	8.8			
MAM.101.DF	9.4			
MAM.101.SINK	3.1			
MAM.102.DF	11.0			
MAM.102.SINK	4.9			
MAM.CORR7.BAT BLVD.DF/BF	1.1			
MAM.103.SINK	3.0			
MAM.104.DF	5.0			
MAM.104.SINK	3.5			
MAM.105.SINK	6.4			
MAM.106.DF	4.9			
MAM.106.SINK	2.2			
MAM.107.DF	5.7			
MAM.107.SINK	1.8			

Location	Results 5/26/16	Results 10/14/16	Results 2/23/17	Comments/Remediation
MAM.108.SINK	9.5			
MAM.109.DF	6.1			
MAM.109.SINK	2.4			
MAM.110.DF	8.8			
MAM.110.SINK	1.9			
MAM.111.DF	8.0			
MAM.111.SINK	2.3			
MAM.112.DF	7.5			
MAM.112.SINK	19.0		<1	
MAM.113.DF	15.0			
MAM.113.SINK	3.2			
MAM.114.DF	9.2			
MAM.114.SINK	2.3			
MAM.115.DF	7.6			
MAM.115.SINK	3.2			
MAM.CORR6.MAIN ST.DF	<1.0			
MAM.117.DF	6.7			
MAM.117.SINK	5.0			
MAM.118.DF	5.3			
MAM.118.SINK	1.9			
MAM.119.DF	11.0			
MAM.119.SINK	3.3			
MAM.120.SINK	2.0			
MAM.121.DF	4.9			
MAM.121.SINK	2.2			
MAM.124.SINK	4.2			
MAM.125.DF	13.0			
MAM.125.SINK	6.2			
MAM.CORR8.ARACHNID AVE.DF	<1.0			
MAM.126.SINK	4.5			
MAM.127.SINK	3.8			
MAM.128.SINK	1.8			
MAM.129.DF	13.0			
MAM.129.SINK	2.1			
MAM.130.SINK	2.4			
MAM.INT.KIT.HANDWASH	5.0			
MAM.INT.KIT.3BAY.RH	16.0	3.6		
MAM.INT.KIT.3BAY.LH	10.0			
MAM.INT.KIT.COMBI	4.6			

Location	Results 5/26/16	Results 10/14/16	Results 2/23/17	Comments/Remediation
MAM.INT.KIT.DISPOSAL	78.0		3.0	
MAM.PRI.KIT.LAV.SINK		8.0		
MAM.127.DF	21.0	6.5		
MAM.22.SINK	23.0	20.2	8.2	
MAM.PRI.KIT.3BAY.LH-R	19.0	22.1	5.1	
MAM.108.DF	43	5.0		
MAM.7.SINK	23	9.2		
MAM.PRI.KIT.COMBI.U-R	16	22.3		Removed from service
MAM.105.DF	24	3.5		
MAM.57.DF	27	14.5		
MAM.19.SINK	20	18.9	6.2	
MAM.COMBI.U-F		2.2		
MAM.54.SINK	26	6.7		
MAM.INT.KIT.3BAY.RH-R		3.6		
MAM.20.SINK	20	7.2		
MAM.54.DF	22	2.0		
MAM.CORR7.BATBLVD.DF/BF		<0.10		
MAM.12.SINK	22	6.8		
MAM.PRI.KIT.DISPOSAL-R	18	21.3	23.7	
MAM.41.SINK	18	25.9	10.7	
MAM.PRI.31.LOCK.SINK		33.5	10.2	
MAM.PRI.1A.LAV.SINK		16.3	4.1	
MAM.PRI.1.NURSE.SINK		16.5	14.6	
MAM.PRI.1B.STORAGE.SINK		50.9	8.2	
MAM.PRI.2A.LAV.SINK		3.8		
MAM.PRI.3.NURSE.LAV.SINK		5.7		
MAM.PRI.5.SINK		16.9	3	
MAM.PRI.5.DF		5.0		
MAM.PRI.HCAP.LAV.RH.SINK		9.5		
MAM.PRI.WOMENS.LAV.LH.SINK		16.5	2.3	
MAM.PRI.WOMENS.LAV.RH.SINK		19.2	3.3	
MAM.PRI.16.CONF.SINK		28.9	1.5	
MAM.INT.116A(DELONG) WORK SINK		14.0		
MAM.INT.116A(DELONG).LAV.SINK		7.8		
MAM.INT.TCHRLOUNGBY124.SINK		2.9		
MAM.INT.131.LAV.SINK		8.2		
MAM.INT.131.KITCH.SINK		90.5	6.8	
MAM.INT.196.LAV.SINK		3.0		
MAM.INT.LIB.SINK		37.6	5.8	

Location	Results 5/26/16	Results 10/14/16	Results 2/23/17	Comments/Remediation
MAM.INT.BOYS.LAV.LH.SINK		3.7		
MAM.INT.BOYS.LAV.RH.SINK		4.0		
MAM.INT.GIRLS.LAV.LH.SINK		3.5		
MAM.INT.GIRLS.LAV.RH.SINK		3.3		
MAM.INT.BOYS.LOCKER.LH.SINK		369.0	2.2	
MAM.INT.BOYS.LOCKER.RH.SINK		8.2		
MAM.INT.GIRLS.LOCKER.LH.SINK		19.3	7	
MAM.INT.GIRLS.LOCKER.RH.SINK		13.1		
MAM.INT.STAGE.STAFF.LAV		4.9		
MAM.INT.132.ISLAND.SINK		89.6	9.1	
MAM.INT.132.LH.SINK		43.1	9.3	
MAM.INT.132.RH.SINK		98.0	9.4	
MAM.EXT.3.BIB		23.9		Used signage to comply
MAM.EXT.102.BIB		1.8		
MAM.EXT.113.BIB		55.0		Used signage to comply
MAM.EXT.127.BIB		119.0		Used signage to comply
MAM.EXT.48.BIB		54.9		Used signage to comply
MAM.EXT.44.BIB		61.0		Used signage to comply
MAM.EXT.41.BIB		58.3		Used signage to comply
MAM.EXT.131.BIB		87.7		Used signage to comply
MAM.EXT.107.BIB		38.9		Used signage to comply
MAM.INT.COACH.SINK		9.3		
MAM.124.DF	18	5.1		
MAM.126.DF	16	10.7		
MAM.103.DF	18	3.0		
MAM.130.DF	19	6.0		
MAM.128.DF	18	6.0		
				0

Location	Results 5/26/16	Results 10/14/16	Results 3/23/17	Comments/ Remediation
EJD.1STFL.KIT.SINK1	6.0			
EJD.1STFL.KIT.SINK2	5.7			
EJD.1STFL.KIT.SINK3	5.5			
EJD.1STFL.KIT.SINK4	12.0			
EJD.1STFL.KIT.KETTLE	15.0			
EJD.1STFL.KIT.COMBI.1U	5.9			
EJD.1STFL.KIT.COMBI.1L	9.9			
EJD.1STFL.KIT.COMBI.2U	4.9			
EJD.1STFL.KIT.COMBI.2L	5			
EJD.1STFL.KIT.SINK5	3.4			
EJD.1STFL.KIT.SINK6	3.5			
EJD.1STFL.KIT.SINK7	5.5			
EJD.1STFL.KIT.SINK8	6.8			
EJD.1STFL.CORR1004.CAFE.WEST.DF	11.0			
EJD.1STFL.CORR1004.CAFE.EAST.DF	34.0			Removed from service
EJD.1STFL.CORR1003.CUST1.DF	1.1			
EJD.1STFL.CORR1006.CUST2.DF	1.8			
EJD.1STFL.GYMSHALL1007.WEST.DF	<1.0			
EJD.1STFL.GYMSHALL1007.EAST.DF	<1.0			
EJD.1STFL.GYM.ELEV.WEST.DF	<1.0			
EJD.1STFL.GYM.ELEV.EAST.DF	<1.0			
EJD.1STFL.PASS173A.WEST.DF	1.7			
EJD.1STFL.PASS173A.EAST.DF	2.0			
EJD.1STFL.ATHLSTOR.ICE	<1.0			
EJD.2NDFL.CUST6.DF	<1.0			
EJD.2NDFL.CORR2010.ELEV.NORTH.DF	<1.0			
EJD.2NDFL.CORR2010.ELEV.SOUTH.DF	1.2			
EJD.1STFL.CORR1004.CAFE.EAST.D		<0.10		
EJD.1STFL.130.M.LAV.SINK		11.3		
EJD.1STFL.130.W.LAV.SINK		14		

Location	Results 5/26/16	Results 10/14/16	Results 3/23/17	Comments/ Remediation
EJD.1STFL.129.1.TCHR.STA.SINK		9.9		
EJD.1STFL.129.2.TCHR.STA.SINK		18.4	5.6	
EJD.1STFL.129.3.REAR.SINK		51.2	33.7	Used signage to comply
EJD.1STFL.127A.SINK		10.2		
EJD.1STFL.127.2.TCHR.STA.SINK		11.4		
EJD.1STFL.127.3.REAR.SINK		75.7	38.2	Used signage to comply
EJD.1STFL.125.1.TCHR.STA.SINK		11		
EJD.1STFL.125.2.REAR.SINK		42.1	5.9	
EJD.1STFL.123A.SINK		55.8	39.1	Used signage to comply
EJD.1STFL.123.1.TCHR.STA.SINK		22.1	19.3	Used signage to comply
EJD.1STFL.123.2.REAR.SINK		50.2	10.1	
EJD.1STFL.BOYS.LAV.RH.SINK		2.6		
EJD.1STFL.GIRLS.LAV.LH.SINK		3.4		
EJD.1STFL.GIRLS.LAV.RH.SINK		3.3		
EJD.1STFL.107B.SINK		8.6		
EJD.1STFL.112A.LAV.M.SINK		11		
EJD.1STFL.112E.LAV.W.SINK		15.4	1.2	
EJD.1STFL.112.FAC.SINK		9.4		
EJD.2NDFL.230.W.LAV.SINK		21.2	<1	
EJD.2NDFL.230.M.LAV.SINK		24	1.1	
EJD.2NDFL.225.LH.SINK		18.7	6.6	
EJD.1STFL.102.A.LAV.SINK		1.4		
EJD.1STFL.100C.LAV.SINK		2.9		
EJD.1STFL.100J.LAV.SINK		4.8		
EJD.1STFL.100A.KITCH.SINK		21.3	1.7	
EJD.1STFL.101.NURSE.SINK		10.5		
EJD.1STFL.101.NURSE.LAV.SINK		7.1		
EJD.1STFL.159.W.FACULTY.LAV.SI		5.9		
EJD.1STFL.157.M.FACULTY.LAV.SI		3.4		
EJD.1STFL.155A.SINK		365	27.2	Used signage to comply

Location	Results 5/26/16	Results 10/14/16	Results 3/23/17	Comments/ Remediation
EJD.1STFL.153.1.LH.SINK		71.3	7.2	
EJD.1STFL.153.2.SINK		33.3	24.6	Used signage to comply
EJD.1STFL.153.3.SINK		71.8	26	Used signage to comply
EJD.1STFL.153.4.RH.SINK		25.7	3.9	
EJD.1STFL.151.1.LH.FAUCET.SINK		9.7		
EJD.1STFL.151.2.RH.FAUCET.SINK		3		
EJD.1STFL.149A.SINK		32.9		Used signage to comply
EJD.1STFL.149.1.LH.FAUCET.SINK		13.7		
EJD.2NDFL.225.RH.SINK		12.5		
EJD.2NDFL.225B.LAV.SINK		1.6		
EJD.2NDFL.221.BOYS.LAV.LH.SINK		2.3		
EJD.2NDFL.221.BOYS.LAV.RH.SINK		1.6		
EJD.2NDFL.219.GIRLS.LAV.LH.SIN		1.5		
EJD.2NDFL.219.GIRLS.LAV.RH.SIN		3.4		
EJD.2NDFL.223.SINK		7		
EJD.1STFL.149.2.RH.FAUCET.SINK		3.8		
EJD.1STFL.179.SINK		24.4	<1	
EJD.1STFL.142.SINK		7.9		
EJD.1STFL.142.DF		3.3		
EJD.1STFL.147.LAV.W.LH.SINK		1.1		
EJD.1STFL.147.W.MID.SINK		1.2		
EJD.1STFL.147.LAV.RH.W.SINK		1.7		
EJD.1STFL.145.LAV.M.LH.SINK		4.4		
EJD.1STFL.145.LAV.M.MID.SINK		1.7		
EJD.1STFL.145.LAV.RH.M.SINK		1.0		
EJD.1STFL.138A.SINK		19.5	10.1	
EJD.1STFL.141A.SINK		17.5	7.8	
EJD.1STFL.181.GIRLS.LAV.LH.SIN		0.86		
EJD.1STFL.181.GIRLS.LAV.RH.SIN		0.96		
EJD.1STFL.183.BOYS.LAV.LH.SINK		1.5		

Location	Results 5/26/16	Results 10/14/16	Results 3/23/17	Comments/ Remediation
EJD.1STFL.183.BOYS.LAV.RH.SINK		2.8		
EJD.1STFL.185.SINK		4.6		
EJD.1STFL.185C.LAV.SINK		1.5		
EJD.1STFL.185.B.LAV.SINK		0.91		
EJD.1STFL.187.1.TCHR.STA.SINK		152	1.5	
EJD.1STFL.187.2.SINK		52.5	<1	
EJD.1STFL.189.1.TCHR.STA.SINK		37.9	17.6	Used signage to comply
EJD.1STFL.189.2.SINK		45.5	1.2	
EJD.1STFL.182.SINK		71.9	<1	
EJD.1STFL.182.DF		2.6		
EJD.1STFL.180.SINK		28.2	<1	
EJD.1STFL.180.DF		4.5		
EJD.1STFL.167.1.W.LH.LAV.SINK		1.7		
EJD.1STFL.167.2.W.LAV.SINK		1.8		
EJD.1STFL.167.3.W.LAV.SINK		4.6		
EJD.1STFL.167.4.W.LAV.SINK		1.4		
EJD.1STFL.167.5.W.LAV.SINK		1.6		
EJD.1STFL.167.6W.RH.LAV.SINK		3.5		
EJD.1STFL.163.1.M.LH.LAV.SINK		2.5		
EJD.1STFL.163.2.M.LAV.SINK		3.9		
EJD.1STFL.163.3.M.LAV.SINK		2.2		
EJD.1STFL.163.4.M.LAV.SINK		8.5		
EJD.1STFL.163.6.M.LAV.RH.SINK		1.1		
EJD.1STFL.163.5.M.LAV.SINK		0.96		
EJD.2NDFL.281.GIRLS.LAV.LH.SIN		1.2		
EJD.2NDFL.281.GIRLS.LAV.RH.SIN		1.2		
EJD.2NDFL.283.BOYS.LAV.LH.SIN		3.5		
EJD.2NDFL.283.BOYS.LAV.RH.SIN		0.78		
EJD.2NDFL.287.1.TCHR.STA.SINK		65.9	4.5	
EJD.2NDFL.287.2.SINK		6.8		

Location	Results 5/26/16	Results 10/14/16	Results 3/20/17	Comments/Remediation
JCB.1STFL.KIT.COMBI.U	7.5			
JCB.1STFL.KIT.COMBI.L	10			
JCB.1STFL.KIT.DISHROOM	20			Removed from service
JCB.1STFL.CORR1006.PE.DF/BF	<1.0			
JCB.1STFL.LAUNDRY.ICEMACHINE	<1.0			
JCB.1STFL.WEIGHTRM.DF	1.5			
JCB.1STFL.CORR1002.LIB.DF.SOUTH	1.1			
JCB.1STFL.CORR1002.LIB.DF.NORTH	5.2			
JCB.1STFL.154.LH	<1.0			
JCB.1STFL.154.RH	<1.0			
JCB.1STFL.146.DF	21			Removed from service
JCB.1STFL.TCHRS.FILTEREDWATER	<1.0			
JCB.1STFL.MAINOFFICE.PREPSINK	7.8			
JCB.1STFL.CORR1010.SCI.DF	1.1			
JCB.2NDFL.CORR2010.SCI.DF	<1.0			
JCB.2NDFL.CORR2003.SOCSTU.DF	1.4			
JCB.CONCESS.DF	1.2			
JCB.CONCESS.HOSEBIB.EXT	9.6			
JCB.1STFL.KIT.3BAYSINK.RH.FAUC	32	17.6	<1	
JCB.1STFL.KIT.3BAYSINK.LH.FAUC	41	24.9	<1	
JCB.1STFL.KIT.KETTLE-R	43	158.0	<1	
JCB.1STFL.KIT.HANDWASH-R	35	10.6		
JCB.1STFL.KIT.DISHROOM-R		39.6		Removed from Service
JCB.1STFL.RECEIVING.FAC.M.LAV		8.1		
JCB.1STFL.RECEIVING.FAC.W.LAV		13.6		
JCB.1STFL.FAC.W.COACH.LAV.SINK		7.9		
JCB.1STFL.GIRLS.LOCKER.LH.1.LA		3.7		
JCB.1STFL.GIRLS.LOCKER.2.LAV		7.9		
JCB.1STFL.GIRLS.LOCKER.3.LAV		3.2		
JCB.1STFL.GIRLS.LOCKER.RH.4.LA		3.3		
JCB.1STFL.GIRLS.TEAM.LH.SINK		3.9		
JCB.1STFL.GIRLS.TEAM.RH.SINK		0.8		

Location	Results 5/26/16	Results 10/14/16	Results 3/20/17	Comments/Remediation
JCB.1STFL.CORR.1006.LH.SINK		2.0		
JCB.1STFL.CORR.1006.MID.SINK		1.0		
JCB.1STFL.CORR.1006.RH.SINK		1.1		
JCB.1STFL.BOYS.LOCKER.2.LAV.SI		1.1		
JCB.1STFL.BOYS.LOCKER.3.LAV.SI		0.6		
JCB.1STFL.BOYS.LOCKER.RH.4.LAV		1.4		
JCB.1STFL.FAC.M.COACH.LAV.SINK		0.4		
JCB.1STFL.127.WASH.LH.SINK		39.3		Removed from Service
JCB.1STFL.127.WASH.MID.SINK		11.9		
JCB.1STFL.127.WASH.RH.SINK		19.7		Removed from Service
JCB.1STFL.128.WASH.LH.SINK		49.4		Removed from Service
JCB.1STFL.128.WASH.MID.SINK		14.6		
JCB.1STFL.128.WASH.RH.SINK		54.4		Removed from Service
JCB.1STFL.SENIOR.LOUNGE.SINK		3.9		
JCB.1STFL.FAC.LIB.W.LH.LAV.SIN		6.5		
JCB.1STFL.FAC.LIB.W.RH.LAV.SIN		3.4		
JCB.1STFL.FAC.LIB.M.LAV.SIN		3.9		
JCB.1STFL.153.TCHR.STA.SINK		55.6		Removed from Service
JCB.1STFL.153.SINK		30.8		Removed from Service
JCB.1STFL.GIRLS.GANG.LH.LAV.SI		1.0		
JCB.1STFL.GIRLS.GANG.MID.LAV		1.8		
JCB.1STFL.GIRLS.GANG.RH.LAV.SI		1.3		
JCB.1STFL.147.LAV.SINK		16.9	4.8	
JCB.1STFL.146.SINK		17.4		Removed from Service
JCB.1STFL.137.SINK		14.4		
JCB.1STFL.BOYS.GANG.LH.LAV.SIN		0.3		
JCB.1STFL.130.FAC.LOUNGE.SINK		4.3		
JCB.1STFL.MO.LAV.SINK		16.9	<1	
JCB.1STFL.STAGE.SINK		72.3	102	Used signage to comply
JCB.1STFL.BOYS.GANG.MID.LAV.SI		0.4		
JCB.1STFL.BOYS.GANG.RH.LAV.SIN		0.4		
JCB.1STFL.NURSE.FRONT.LAV.SINK		13.0		

Location	Results 5/26/16	Results 10/14/16	Results 3/20/17	Comments/Remediation
JCB.1STFL.NURSE.REAR.LAV.SINK		12.6		
JCB.1STFL.NURSE.HAND.WASH.SINK		4.9		
JCB.1STFL.133.LH.SINK		11.0		
JCB.1STFL.133.RH.SINK		1.6		
JCB.1STFL.132.LH.SINK		4.1		
JCB.1STFL.132.RH.SINK		4.6		
JCB.1STFL.131.SINK		1.2		
JCB.1STFL.131.FILM.ROOM.SINK		9.0		
JCB.1STFL.131.DARK.ROO.SINK		94.1	<1	
JCB.1STFL.170.1.TCHR.STA.SINK		18.0	<1	
JCB.1STFL.170.2.LH.SIDE.SINK		14.6		
JCB.1STFL.170.3.LH.REAR.SINK		3.9		
JCB.1STFL.170.4.RH.REAR.SINK		6.1		
JCB.1STFL.170.5.RH.SIDE.SINK		7.9		
JCB.1STFL.171.SINK		36.1	<1	
JCB.1STFL.172.1.LH.SIDE.SINK		20.6	1	
JCB.1STFL.172.2.LH.REAR.SINK		7.0		
JCB.1STFL.172.3.RH.REAR.SINK		9.5		
JCB.1STFL.172.4.RH.SIDE.SINK		15.6	2.1	
JCB.1STFL.173.1.TCHR.STA.SINK		24.2	<1	
JCB.1STFL.173.2.LH.SIDE.SINK		16.1	1	
JCB.1STFL.173.3.LH.REAR.SINK		7.3		
JCB.1STFL.173.4.RH.REAR.SINK		18.2	1.1	
JCB.1STFL.173.5.RH.SIDE.SINK		14.3		
JCB.1STFL.174.SINK		73.2	2	
JCB.1STFL.175.1.TCHR.STA.SINK		11.0		
JCB.1STFL.175.2.LH.SIDE.SINK		7.2		
JCB.1STFL.175.3.LH.REAR.SINK		8.9		
JCB.1STFL.175.4.RH.REAR.SINK		14.7		
JCB.1STFL.175.5.RH.SIDE.SINK		13.8		
JCB.1STFL.SCI.FAC.LAV.SINK		1.5		
JCB.2NDFL.2003.SOC.STU.DF		<0.10		

Location	Results 5/26/16	Results 10/14/16	Results 3/20/17	Comments/Remediation
JCB.2NDFL.BOYS.GANG.LH.LAV.SIN		0.7		
JCB.2NDFL.BOYS.GANG.MID.LAV.SI		0.7		
JCB.2NDFL.BOYS.GANG.RH.LAV.SIN		1.1		
JCB.2NDFL.FAC.LAV.SINK		2.4		
JCB.2NDFL.227.SINK		110.0	19.3	Used signage to comply
		0.9		
JCB.2NDFL.GIRLS.GANG.3.LAV.SIN		0.8		
JCB.2NDFL.GIRLS.GANG.4.RH.LAV		1.0		
JCB.2NDFL.FAC.SCI.LAV.SINK		2.6		
JCB.2NDFL.270.1.TCHR.STA.SINK		14.5		
JCB.2NDFL.270.2.DOOR.108.SINK		14.6		
JCB.2NDFL.270.3.DOOR.118.SINK		12.8		
JCB.2NDFL.270.4.DOOR.128.SINK		7.6		
JCB.2NDFL.270.5.DOOR.134.SINK		11.1		
JCB.2NDFL.270.6.DOOR.142.SINK		24.3	7	
JCB.2NDFL.270.7.DOOR.164.SINK		9.2		
JCB.2NDFL.270.8.DOOR.171.SINK		19.4	8.8	
JCB.2NDFL.270.9.HOOD.SINK		13.9		
JCB.2NDFL.270.10.ISLAND.SINK		11.3		
JCB.2NDFL.271.SINK		39.7		Used signage to comply
JCB.2NDFL.272.1.TCHR.STA.SINK		28.0	3.4	
JCB.2NDFL.272.2.HOOD.SINK		38.5	8	
JCB.2NDFL.272.3.DOOR.112.SINK		72.6	14.5	
JCB.2NDFL.272.4.DOOR.119.SINK		18.2	8.5	
JCB.2NDFL.272.5.DOOR.141.SINK		17.7	4.6	
JCB.2NDFL.272.6.DOOR.149.SINK		19.5	8.5	
JCB.2NDFL.272.7.DOOR.155.SINK		21.9	6.6	
JCB.2NDFL.272.8.DOOR.165.SINK		38.3	9.7	
JCB.2NDFL.272.9.DOOR.175.SINK		33.1	8.8	
JCB.2NDFL.272.10.ISLAND.SINK		11.4		
JCB.2NDFL.273.1.LH.SIDE.SINK		24.1	3.8	
JCB.2NDFL.273.2.LH.REAR.SINK		12.8		

